

Hervey Bay retic data (Jun 2014- Jun 2015)	Manganese	Copper	Escherichia Chlorine	Free Chlorine	Aluminium	Iron	pH	Total Hardness	True Colour	Turbidity	Zinc
Result (max/min)	0.027	1.9	<1	3.7/0.01	0.058	0.315	8.15.8	90	6	7.4	0.166
Guideline value, ADWG (2004)	0.5mg/L	2mg/L	Zero in 100mL	5mg/L	0.2mg/L	0.3mg/L	6.5 - 8.5	60 - 200 acceptable	<15 TCU	<5 NTU	3mg/L
95th percentile	<0.01	0.076	<1	2.4	0.052	0.035	8.03	74	0	0.42	0.019
Number of samples tested	615	615	1166	1166	615	615	615	615	615	616	615
Number of exceedanc es of guideline value	0	0	0	0	0	0	0	0	0	0	0
% Compliance with ADWG	100%	100%	100%	100%	100%	100%	100%	N/A	100%	99.83%	100%