

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG1.4a	AS1	Number water treatment plants: providing full treatment	2	Count
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG1.1	AS2	Length water mains	834.4	km
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG1.4b	AS47	Capacity of water treatment plants	54	ML/day
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG1.7	AS48	Total potable water storage volume	76.52	ML
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG1.23	AS56	Volume water lost: potable water	477.4	ML
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG4.5	AS8	Water main breaks per 100 km water main	5.9	per 100 km water main
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG4.12	CS10	Water service complaints per 1000 connections	8.3	per 1000 connections
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0.1	per 1000 connections
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	11.1	per 1000 connections
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG4.7	CS17	Average frequency unplanned interruptions: water	33.7	per 1000 connections

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG1.13	CS2	Connected residential properties: water	27.49	000s
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG1.14	CS3	Connected non-residential properties: water	1.849	000s
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG4.8a	CS66	Percent CSS response target met: water incidents	100	%
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG4.10	CS9	Water quality complaints per 1000 connections	2.1	per 1000 connections
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG4.1(value)	PR3	Fixed charge: water value	484.5	\$/annum
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG4.1(text)	PR5	Fixed charge: water description	Water Access	Text
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG1.8	WA1	Volume water sourced: surface water	7657	ML
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG1.9a	WA2	Volume water sourced: groundwater	NR	ML
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG1.5	WA201	Maximum daily demand	33.6	ML/day
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG1.21	WA223	Volume all water imported: internal and external	0	ML

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG1.22	WA224	Volume all water exported: internal and external	0	ML
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG1.6a	WA225	Volume potable water produced at a water treatment plant	7578	ML
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG1.17a	WA32	Volume potable water supplied: residential	5158	ML
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG1.18a	WA34	Volume potable water supplied: non-residential	1373.5	ML
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG1.10	WA61	Volume water sourced: desalination marine water	NR	ML
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG1.12	WA7	Volume water sourced: all	7657	ML
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG2.10a	WS11	Water restriction duration: PWCM	126	days
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG2.10b	WS12	Water restriction duration: Level 1	145	days
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG2.10c	WS13	Water restriction duration: Level 2	94	days
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG2.10d	WS14	Water restriction duration: Level 3	0	days

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG2.10e	WS15	Water restriction duration: Level 4	0	days
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG2.10f	WS16	Water restriction duration: Level 5	0	days
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG2.11a	WS17	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG2.11b	WS18	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG2.11c	WS19	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG2.11d	WS20	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG2.11e	WS21	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	yes	yes/no
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG2.12	WS22	Months water supply remaining as at 30 June (KPI level)	5	1,2,3,4,5,6
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG2.13	WS23	Confidence water demand will be met: next 18 mths	high	high,fair,unsure,low,very low
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG2.14	WS24	Confidence water demand will be met: next 5 yrs	fair	high,fair,unsure,low,very low

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	11838	Hervey Bay PW	QG2.3	WS3	Available contingency supplies	yes	yes/no
2021	Fraser Coast Regional Council	221	Teddington WTP	QG1.4a	AS1	Number water treatment plants: providing full treatment	1	Count
2021	Fraser Coast Regional Council	221	Teddington WTP	QG1.1	AS2	Length water mains	275.3	km
2021	Fraser Coast Regional Council	221	Teddington WTP	QG1.4b	AS47	Capacity of water treatment plants	18	ML/day
2021	Fraser Coast Regional Council	221	Teddington WTP	QG1.7	AS48	Total potable water storage volume	25.493	ML
2021	Fraser Coast Regional Council	221	Teddington WTP	QG1.23	AS56	Volume water lost: potable water	502.8	ML
2021	Fraser Coast Regional Council	221	Teddington WTP	QG4.5	AS8	Water main breaks per 100 km water main	5.1	per 100 km water main
2021	Fraser Coast Regional Council	221	Teddington WTP	QG4.12	CS10	Water service complaints per 1000 connections	8.4	per 1000 connections
2021	Fraser Coast Regional Council	221	Teddington WTP	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0.1	per 1000 connections
2021	Fraser Coast Regional Council	221	Teddington WTP	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	11.4	per 1000 connections

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	221	Teddington WTP	QG4.7	CS17	Average frequency unplanned interruptions: water	14.4	per 1000 connections
2021	Fraser Coast Regional Council	221	Teddington WTP	QG1.13	CS2	Connected residential properties: water	9.079	000s
2021	Fraser Coast Regional Council	221	Teddington WTP	QG1.14	CS3	Connected non-residential properties: water	1.012	000s
2021	Fraser Coast Regional Council	221	Teddington WTP	QG4.8a	CS66	Percent CSS response target met: water incidents	100	%
2021	Fraser Coast Regional Council	221	Teddington WTP	QG4.10	CS9	Water quality complaints per 1000 connections	2.2	per 1000 connections
2021	Fraser Coast Regional Council	221	Teddington WTP	QG4.1(value)	PR3	Fixed charge: water value	484.5	\$/annum
2021	Fraser Coast Regional Council	221	Teddington WTP	QG4.1(text)	PR5	Fixed charge: water description	Water Access	Text
2021	Fraser Coast Regional Council	221	Teddington WTP	QG1.8	WA1	Volume water sourced: surface water	3357	ML
2021	Fraser Coast Regional Council	221	Teddington WTP	QG1.9a	WA2	Volume water sourced: groundwater	NR	ML
2021	Fraser Coast Regional Council	221	Teddington WTP	QG1.5	WA201	Maximum daily demand	15.3	ML/day

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	221	Teddington WTP	QG1.21	WA223	Volume all water imported: internal and external	0	ML
2021	Fraser Coast Regional Council	221	Teddington WTP	QG1.22	WA224	Volume all water exported: internal and external	0	ML
2021	Fraser Coast Regional Council	221	Teddington WTP	QG1.6a	WA225	Volume potable water produced at a water treatment plant	2903.2	ML
2021	Fraser Coast Regional Council	221	Teddington WTP	QG1.17a	WA32	Volume potable water supplied: residential	1651.3	ML
2021	Fraser Coast Regional Council	221	Teddington WTP	QG1.18a	WA34	Volume potable water supplied: non-residential	617.6	ML
2021	Fraser Coast Regional Council	221	Teddington WTP	QG1.10	WA61	Volume water sourced: desalination marine water	NR	ML
2021	Fraser Coast Regional Council	221	Teddington WTP	QG1.12	WA7	Volume water sourced: all	3357	ML
2021	Fraser Coast Regional Council	221	Teddington WTP	QG2.10a	WS11	Water restriction duration: PWCM	126	days
2021	Fraser Coast Regional Council	221	Teddington WTP	QG2.10b	WS12	Water restriction duration: Level 1	145	days
2021	Fraser Coast Regional Council	221	Teddington WTP	QG2.10c	WS13	Water restriction duration: Level 2	94	days

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	221	Teddington WTP	QG2.10d	WS14	Water restriction duration: Level 3	0	days
2021	Fraser Coast Regional Council	221	Teddington WTP	QG2.10e	WS15	Water restriction duration: Level 4	0	days
2021	Fraser Coast Regional Council	221	Teddington WTP	QG2.10f	WS16	Water restriction duration: Level 5	0	days
2021	Fraser Coast Regional Council	221	Teddington WTP	QG2.11a	WS17	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no
2021	Fraser Coast Regional Council	221	Teddington WTP	QG2.11b	WS18	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no
2021	Fraser Coast Regional Council	221	Teddington WTP	QG2.11c	WS19	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no
2021	Fraser Coast Regional Council	221	Teddington WTP	QG2.11d	WS20	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no
2021	Fraser Coast Regional Council	221	Teddington WTP	QG2.11e	WS21	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	yes	yes/no
2021	Fraser Coast Regional Council	221	Teddington WTP	QG2.12	WS22	Months water supply remaining as at 30 June (KPI level)	5	1,2,3,4,5,6
2021	Fraser Coast Regional Council	221	Teddington WTP	QG2.13	WS23	Confidence water demand will be met: next 18 mths	fair	high,fair,unsure,low,very low

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	221	Teddington WTP	QG2.14	WS24	Confidence water demand will be met: next 5 yrs	fair	high,fair,unsure,low,very low
2021	Fraser Coast Regional Council	221	Teddington WTP	QG2.3	WS3	Available contingency supplies	yes	yes/no
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG1.4a	AS1	Number water treatment plants: providing full treatment	1	Count
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG1.1	AS2	Length water mains	11.1	km
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG1.4b	AS47	Capacity of water treatment plants	0.7	ML/day
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG1.7	AS48	Total potable water storage volume	1.816	ML
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG1.23	AS56	Volume water lost: potable water	1.7	ML
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG4.5	AS8	Water main breaks per 100 km water main	0	per 100 km water main
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG4.12	CS10	Water service complaints per 1000 connections	10.2	per 1000 connections
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	13.7	per 1000 connections
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG4.7	CS17	Average frequency unplanned interruptions: water	0	per 1000 connections
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG1.13	CS2	Connected residential properties: water	0.25	000s
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG1.14	CS3	Connected non-residential properties: water	0.043	000s
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG4.8a	CS66	Percent CSS response target met: water incidents	100	%
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG4.10	CS9	Water quality complaints per 1000 connections	0	per 1000 connections
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG4.1(value)	PR3	Fixed charge: water value	484.5	\$/annum
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG4.1(text)	PR5	Fixed charge: water description	Water Access	Text
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG1.8	WA1	Volume water sourced: surface water	61	ML
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG1.9a	WA2	Volume water sourced: groundwater	NR	ML

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG1.5	WA201	Maximum daily demand	0.3	ML/day
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG1.21	WA223	Volume all water imported: internal and external	0	ML
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG1.22	WA224	Volume all water exported: internal and external	0	ML
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG1.6a	WA225	Volume potable water produced at a water treatment plant	56.3	ML
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG1.17a	WA32	Volume potable water supplied: residential	34.7	ML
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG1.18a	WA34	Volume potable water supplied: non-residential	14.4	ML
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG1.10	WA61	Volume water sourced: desalination marine water	NR	ML
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG1.12	WA7	Volume water sourced: all	61	ML
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG2.10a	WS11	Water restriction duration: PWCM	126	days
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG2.10b	WS12	Water restriction duration: Level 1	145	days

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG2.10c	WS13	Water restriction duration: Level 2	94	days
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG2.10d	WS14	Water restriction duration: Level 3	0	days
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG2.10e	WS15	Water restriction duration: Level 4	0	days
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG2.10f	WS16	Water restriction duration: Level 5	0	days
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG2.11a	WS17	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG2.11b	WS18	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG2.11c	WS19	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG2.11d	WS20	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG2.11e	WS21	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	yes	yes/no
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG2.12	WS22	Months water supply remaining as at 30 June (KPI level)	5	1,2,3,4,5,6

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG2.13	WS23	Confidence water demand will be met: next 18 mths	high	high,fair,unsure,low,very low
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG2.14	WS24	Confidence water demand will be met: next 5 yrs	high	high,fair,unsure,low,very low
2021	Fraser Coast Regional Council	1277	Tiaro WTP	QG2.3	WS3	Available contingency supplies	yes	yes/no
2021	Fraser Coast Regional Council	9630	Aubinville Reuse	QG1.1	AS2	Length water mains	17.7	km
2021	Fraser Coast Regional Council	9630	Aubinville Reuse	QG4.5	AS8	Water main breaks per 100 km water main	0	per 100 km water main
2021	Fraser Coast Regional Council	9630	Aubinville Reuse	QG4.12	CS10	Water service complaints per 1000 connections	0	per 1000 connections
2021	Fraser Coast Regional Council	9630	Aubinville Reuse	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections
2021	Fraser Coast Regional Council	9630	Aubinville Reuse	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections
2021	Fraser Coast Regional Council	9630	Aubinville Reuse	QG1.13	CS2	Connected residential properties: water	0	000s
2021	Fraser Coast Regional Council	9630	Aubinville Reuse	QG1.14	CS3	Connected non-residential properties: water	0.046	000s

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	9630	Aubinville Reuse	QG4.10	CS9	Water quality complaints per 1000 connections	0	per 1000 connections
2021	Fraser Coast Regional Council	9630	Aubinville Reuse	QG4.1(value)	PR3	Fixed charge: water value	0	\$/annum
2021	Fraser Coast Regional Council	9630	Aubinville Reuse	QG4.1(text)	PR5	Fixed charge: water description	0	Text
2021	Fraser Coast Regional Council	9630	Aubinville Reuse	QG1.21	WA223	Volume all water imported: internal and external	0	ML
2021	Fraser Coast Regional Council	9630	Aubinville Reuse	QG1.22	WA224	Volume all water exported: internal and external	0	ML
2021	Fraser Coast Regional Council	9630	Aubinville Reuse	QG1.11	WA26	Volume recycled sewage supplied: all	1357.3	ML
2021	Fraser Coast Regional Council	9630	Aubinville Reuse	QG1.12	WA7	Volume water sourced: all	1357.3	ML
2021	Fraser Coast Regional Council	9731	Burrum Heads effluent reuse	QG1.1	AS2	Length water mains	6.5	km
2021	Fraser Coast Regional Council	9731	Burrum Heads effluent reuse	QG4.5	AS8	Water main breaks per 100 km water main	0	per 100 km water main
2021	Fraser Coast Regional Council	9731	Burrum Heads effluent reuse	QG4.12	CS10	Water service complaints per 1000 connections	0	per 1000 connections

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	9731	Burrum Heads effluent reuse	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections
2021	Fraser Coast Regional Council	9731	Burrum Heads effluent reuse	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections
2021	Fraser Coast Regional Council	9731	Burrum Heads effluent reuse	QG1.13	CS2	Connected residential properties: water	0	000s
2021	Fraser Coast Regional Council	9731	Burrum Heads effluent reuse	QG1.14	CS3	Connected non-residential properties: water	0.001	000s
2021	Fraser Coast Regional Council	9731	Burrum Heads effluent reuse	QG4.10	CS9	Water quality complaints per 1000 connections	0	per 1000 connections
2021	Fraser Coast Regional Council	9731	Burrum Heads effluent reuse	QG4.1(value)	PR3	Fixed charge: water value	0	\$/annum
2021	Fraser Coast Regional Council	9731	Burrum Heads effluent reuse	QG4.1(text)	PR5	Fixed charge: water description	0	Text
2021	Fraser Coast Regional Council	9731	Burrum Heads effluent reuse	QG1.21	WA223	Volume all water imported: internal and external	0	ML
2021	Fraser Coast Regional Council	9731	Burrum Heads effluent reuse	QG1.22	WA224	Volume all water exported: internal and external	0	ML
2021	Fraser Coast Regional Council	9731	Burrum Heads effluent reuse	QG1.11	WA26	Volume recycled sewage supplied: all	100.1	ML

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	9731	Burrum Heads effluent reuse	QG1.12	WA7	Volume water sourced: all	100.1	ML
2021	Fraser Coast Regional Council	11839	Hervey Bay Reuse	QG1.1	AS2	Length water mains	42.7	km
2021	Fraser Coast Regional Council	11839	Hervey Bay Reuse	QG4.5	AS8	Water main breaks per 100 km water main	0	per 100 km water main
2021	Fraser Coast Regional Council	11839	Hervey Bay Reuse	QG4.12	CS10	Water service complaints per 1000 connections	0	per 1000 connections
2021	Fraser Coast Regional Council	11839	Hervey Bay Reuse	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections
2021	Fraser Coast Regional Council	11839	Hervey Bay Reuse	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections
2021	Fraser Coast Regional Council	11839	Hervey Bay Reuse	QG1.13	CS2	Connected residential properties: water	0	000s
2021	Fraser Coast Regional Council	11839	Hervey Bay Reuse	QG1.14	CS3	Connected non-residential properties: water	0.038	000s
2021	Fraser Coast Regional Council	11839	Hervey Bay Reuse	QG4.10	CS9	Water quality complaints per 1000 connections	0	per 1000 connections
2021	Fraser Coast Regional Council	11839	Hervey Bay Reuse	QG4.1(value)	PR3	Fixed charge: water value	0	\$/annum

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	11839	Hervey Bay Reuse	QG4.1(text)	PR5	Fixed charge: water description	0	Text
2021	Fraser Coast Regional Council	11839	Hervey Bay Reuse	QG1.21	WA223	Volume all water imported: internal and external	0	ML
2021	Fraser Coast Regional Council	11839	Hervey Bay Reuse	QG1.22	WA224	Volume all water exported: internal and external	0	ML
2021	Fraser Coast Regional Council	11839	Hervey Bay Reuse	QG1.11	WA26	Volume recycled sewage supplied: all	3347	ML
2021	Fraser Coast Regional Council	11839	Hervey Bay Reuse	QG1.12	WA7	Volume water sourced: all	3347	ML
2021	Fraser Coast Regional Council	9729	Howard effluent reuse	QG1.1	AS2	Length water mains	2.7	km
2021	Fraser Coast Regional Council	9729	Howard effluent reuse	QG4.5	AS8	Water main breaks per 100 km water main	0	per 100 km water main
2021	Fraser Coast Regional Council	9729	Howard effluent reuse	QG4.12	CS10	Water service complaints per 1000 connections	0	per 1000 connections
2021	Fraser Coast Regional Council	9729	Howard effluent reuse	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections
2021	Fraser Coast Regional Council	9729	Howard effluent reuse	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	9729	Howard effluent reuse	QG1.13	CS2	Connected residential properties: water	0	000s
2021	Fraser Coast Regional Council	9729	Howard effluent reuse	QG1.14	CS3	Connected non-residential properties: water	0.001	000s
2021	Fraser Coast Regional Council	9729	Howard effluent reuse	QG4.10	CS9	Water quality complaints per 1000 connections	0	per 1000 connections
2021	Fraser Coast Regional Council	9729	Howard effluent reuse	QG4.1(value)	PR3	Fixed charge: water value	0	\$/annum
2021	Fraser Coast Regional Council	9729	Howard effluent reuse	QG4.1(text)	PR5	Fixed charge: water description	0	Text
2021	Fraser Coast Regional Council	9729	Howard effluent reuse	QG1.21	WA223	Volume all water imported: internal and external	0	ML
2021	Fraser Coast Regional Council	9729	Howard effluent reuse	QG1.22	WA224	Volume all water exported: internal and external	0	ML
2021	Fraser Coast Regional Council	9729	Howard effluent reuse	QG1.11	WA26	Volume recycled sewage supplied: all	8.3	ML
2021	Fraser Coast Regional Council	9729	Howard effluent reuse	QG1.12	WA7	Volume water sourced: all	8.3	ML
2021	Fraser Coast Regional Council	9727	Toogoom effluent reuse	QG1.1	AS2	Length water mains	0.6	km

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	9727	Toogoom effluent reuse	QG4.5	AS8	Water main breaks per 100 km water main	0	per 100 km water main
2021	Fraser Coast Regional Council	9727	Toogoom effluent reuse	QG4.12	CS10	Water service complaints per 1000 connections	0	per 1000 connections
2021	Fraser Coast Regional Council	9727	Toogoom effluent reuse	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections
2021	Fraser Coast Regional Council	9727	Toogoom effluent reuse	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections
2021	Fraser Coast Regional Council	9727	Toogoom effluent reuse	QG1.13	CS2	Connected residential properties: water	0	000s
2021	Fraser Coast Regional Council	9727	Toogoom effluent reuse	QG1.14	CS3	Connected non-residential properties: water	0.002	000s
2021	Fraser Coast Regional Council	9727	Toogoom effluent reuse	QG4.10	CS9	Water quality complaints per 1000 connections	0	per 1000 connections
2021	Fraser Coast Regional Council	9727	Toogoom effluent reuse	QG4.1(value)	PR3	Fixed charge: water value	0	\$/annum
2021	Fraser Coast Regional Council	9727	Toogoom effluent reuse	QG4.1(text)	PR5	Fixed charge: water description	0	Text
2021	Fraser Coast Regional Council	9727	Toogoom effluent reuse	QG1.21	WA223	Volume all water imported: internal and external	0	ML

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	9727	Toogoom effluent reuse	QG1.22	WA224	Volume all water exported: internal and external	0	ML
2021	Fraser Coast Regional Council	9727	Toogoom effluent reuse	QG1.11	WA26	Volume recycled sewage supplied: all	51.2	ML
2021	Fraser Coast Regional Council	9727	Toogoom effluent reuse	QG1.12	WA7	Volume water sourced: all	51.2	ML
2021	Fraser Coast Regional Council	9726	Torbanlea effluent reuse	QG1.1	AS2	Length water mains	2.2	km
2021	Fraser Coast Regional Council	9726	Torbanlea effluent reuse	QG4.5	AS8	Water main breaks per 100 km water main	0	per 100 km water main
2021	Fraser Coast Regional Council	9726	Torbanlea effluent reuse	QG4.12	CS10	Water service complaints per 1000 connections	0	per 1000 connections
2021	Fraser Coast Regional Council	9726	Torbanlea effluent reuse	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections
2021	Fraser Coast Regional Council	9726	Torbanlea effluent reuse	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections
2021	Fraser Coast Regional Council	9726	Torbanlea effluent reuse	QG1.13	CS2	Connected residential properties: water	0	000s
2021	Fraser Coast Regional Council	9726	Torbanlea effluent reuse	QG1.14	CS3	Connected non-residential properties: water	0.003	000s

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	9726	Torbanlea effluent reuse	QG4.10	CS9	Water quality complaints per 1000 connections	0	per 1000 connections
2021	Fraser Coast Regional Council	9726	Torbanlea effluent reuse	QG4.1(value)	PR3	Fixed charge: water value	0	\$/annum
2021	Fraser Coast Regional Council	9726	Torbanlea effluent reuse	QG4.1(text)	PR5	Fixed charge: water description	0	Text
2021	Fraser Coast Regional Council	9726	Torbanlea effluent reuse	QG1.21	WA223	Volume all water imported: internal and external	0	ML
2021	Fraser Coast Regional Council	9726	Torbanlea effluent reuse	QG1.22	WA224	Volume all water exported: internal and external	0	ML
2021	Fraser Coast Regional Council	9726	Torbanlea effluent reuse	QG1.11	WA26	Volume recycled sewage supplied: all	15.8	ML
2021	Fraser Coast Regional Council	9726	Torbanlea effluent reuse	QG1.12	WA7	Volume water sourced: all	15.8	ML
2021	Fraser Coast Regional Council	222	Aubinville WWTP	QG4.6	AS39	Sewerage mains breaks/chokes per 100 km sewer main	8.8	per 100 km sewer mains
2021	Fraser Coast Regional Council	222	Aubinville WWTP	QG1.3	AS4	Number sewage treatment plants	1	Count
2021	Fraser Coast Regional Council	222	Aubinville WWTP	QG1.2	AS5	Length sewerage mains and channels	249.9	km

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	222	Aubinville WWTP	QG4.13	CS11	Sewerage service complaints per 1000 connections	4.8	per 1000 connections
2021	Fraser Coast Regional Council	222	Aubinville WWTP	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections
2021	Fraser Coast Regional Council	222	Aubinville WWTP	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	6.9	per 1000 connections
2021	Fraser Coast Regional Council	222	Aubinville WWTP	QG1.15	CS6	Connected residential properties: sewerage	9.09	000s
2021	Fraser Coast Regional Council	222	Aubinville WWTP	QG4.9a	CS65	Percent CSS response target met: sewerage incidents	100	%
2021	Fraser Coast Regional Council	222	Aubinville WWTP	QG1.16	CS7	Connected non-residential properties: sewerage	0.967	000s
2021	Fraser Coast Regional Council	222	Aubinville WWTP	QG4.2(value)	PR31	Fixed charge: sewerage value	759.9	\$/annum
2021	Fraser Coast Regional Council	222	Aubinville WWTP	QG4.2(text)	PR40	Fixed charge: sewerage description	Sewer Access Charge	Text
2021	Fraser Coast Regional Council	11843	Hervey Bay Sewerage	QG4.6	AS39	Sewerage mains breaks/chokes per 100 km sewer main	5.4	per 100 km sewer mains
2021	Fraser Coast Regional Council	11843	Hervey Bay Sewerage	QG1.3	AS4	Number sewage treatment plants	7	Count

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	11843	Hervey Bay Sewerage	QG1.2	AS5	Length sewerage mains and channels	555.6	km
2021	Fraser Coast Regional Council	11843	Hervey Bay Sewerage	QG4.13	CS11	Sewerage service complaints per 1000 connections	4.8	per 1000 connections
2021	Fraser Coast Regional Council	11843	Hervey Bay Sewerage	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections
2021	Fraser Coast Regional Council	11843	Hervey Bay Sewerage	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	6.9	per 1000 connections
2021	Fraser Coast Regional Council	11843	Hervey Bay Sewerage	QG1.15	CS6	Connected residential properties: sewerage	23.021	000s
2021	Fraser Coast Regional Council	11843	Hervey Bay Sewerage	QG4.9a	CS65	Percent CSS response target met: sewerage incidents	100	%
2021	Fraser Coast Regional Council	11843	Hervey Bay Sewerage	QG1.16	CS7	Connected non-residential properties: sewerage	1.319	000s
2021	Fraser Coast Regional Council	11843	Hervey Bay Sewerage	QG4.2(value)	PR31	Fixed charge: sewerage value	759.9	\$/annum
2021	Fraser Coast Regional Council	11843	Hervey Bay Sewerage	QG4.2(text)	PR40	Fixed charge: sewerage description	Sewer Access Charge	Text
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG1.4a	AS1	Number water treatment plants: providing full treatment	4	Count

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG1.1	AS2	Length water mains	1193.2	km
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG4.6	AS39	Sewerage mains breaks/chokes per 100 km sewer main	6.5	per 100 km sewer mains
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG1.3	AS4	Number sewage treatment plants	8	Count
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG1.4b	AS47	Capacity of water treatment plants	72.7	ML/day
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG1.7	AS48	Total potable water storage volume	103.829	ML
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG1.2	AS5	Length sewerage mains and channels	805.4	km
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG1.23	AS56	Volume water lost: potable water	981.9	ML
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG4.5	AS8	Water main breaks per 100 km water main	5.3	per 100 km water main
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG4.12	CS10	Water service complaints per 1000 connections	8.4	per 1000 connections
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG4.13	CS11	Sewerage service complaints per 1000 connections	4.8	per 1000 connections

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0.1	per 1000 connections
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	17.2	per 1000 connections
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG4.7	CS17	Average frequency unplanned interruptions: water	28.6	per 1000 connections
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG1.13	CS2	Connected residential properties: water	36.819	000s
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG1.14	CS3	Connected non-residential properties: water	2.904	000s
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG1.15	CS6	Connected residential properties: sewerage	32.111	000s
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG4.9a	CS65	Percent CSS response target met: sewerage incidents	100	%
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG4.8a	CS66	Percent CSS response target met: water incidents	100	%
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG1.16	CS7	Connected non-residential properties: sewerage	2.286	000s
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG4.10	CS9	Water quality complaints per 1000 connections	2.1	per 1000 connections

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG3.9	FN1	Revenue: all (NPR) water	49226.8	\$,000
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG3.6	FN10	Nominal written down replacement cost: fixed sewerage assets	402559	\$,000
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG3.11	FN11	Costs: operating water per connection	415.23	\$/connection
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG3.12	FN12	Costs: operating sewerage per connection	426.48	\$/connection
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG3.1	FN14	Capital expenditure: water supply	12663.3	\$,000
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG3.2	FN15	Capital expenditure: sewerage	17683.7	\$,000
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG3.10	FN2	Revenue: all (NPR) sewerage	45701.5	\$,000
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG3.3	FN26	Capital works grants: water	1344.95	\$,000
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG3.4	FN27	Capital works grants: sewerage	1970.04	\$,000
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG3.11a	FN32	Costs: operating water (NPR)	16494.2	\$,000

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG3.12a	FN33	Costs: operating sewerage	14669.5	\$,000
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG3.21	FN49	Costs: any other water	15192.5	\$,000
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG3.22	FN50	Costs: any other sewerage	13856.5	\$,000
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG3.7	FN74	Current replacement costs: fixed water assets	751696	\$,000
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG3.8	FN75	Current replacement costs: fixed sewerage assets	671611	\$,000
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG3.13	FN76	Costs: maintenance water	15562.9	\$,000
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG3.14	FN77	Costs: maintenance sewerage	12468	\$,000
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG3.15	FN78	Current cost depreciation: water	13958	\$,000
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG3.16	FN79	Current cost depreciation: sewerage	12356	\$,000
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG3.17	FN80	Previous 5 year average annual renewals expenditure: water	6407.25	\$,000

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG3.18	FN81	Previous 5 year average annual renewals expenditure: sewerage	4365.41	\$,000
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG3.19	FN82	Forecast 5 year average annual renewals expenditure: water	6681.24	\$,000
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG3.20	FN83	Forecast 5 year average annual renewals expenditure: sewerage	4672.15	\$,000
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG3.5	FN9	Nominal written down replacement cost: fixed water assets	446063	\$,000
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG4.1(value)	PR3	Fixed charge: water value	484.5	\$/annum
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG4.2(value)	PR31	Fixed charge: sewerage value	759.9	\$/annum
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG4.2(text)	PR40	Fixed charge: sewerage description	Sewer Access Charge	Text
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG4.3	PR47	Annual bill based on 200kL/a: water+sewerage	1626.4	\$
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG4.4	PR48	Typical residential bill: water+sewerage	1601.19	\$
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG4.1(text)	PR5	Fixed charge: water description	Water Access	Text

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG1.8	WA1	Volume water sourced: surface water	11075	ML
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG1.9a	WA2	Volume water sourced: groundwater	0	ML
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG1.5	WA201	Maximum daily demand	49.2	ML/day
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG1.21	WA223	Volume all water imported: internal and external	0	ML
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG1.22	WA224	Volume all water exported: internal and external	0	ML
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG1.6a	WA225	Volume potable water produced at a water treatment plant	10537.5	ML
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG1.11	WA26	Volume recycled sewage supplied: all	4879.7	ML
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG1.17a	WA32	Volume potable water supplied: residential	6844	ML
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG1.18a	WA34	Volume potable water supplied: non-residential	2005.4	ML
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG1.10	WA61	Volume water sourced: desalination marine water	0	ML

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG1.12	WA7	Volume water sourced: all	15954.7	ML
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG1.17b	WA91	Volume raw-PT water supplied: residential	NR	ML
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG1.18b	WA92	Volume raw-PT water supplied: non-residential	NR	ML
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG1.20	WF1	Total full-time equivalent water+sewerage employees	175	FTEs
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG2.10a	WS11	Water restriction duration: PWCM	126	days
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG2.10b	WS12	Water restriction duration: Level 1	145	days
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG2.10c	WS13	Water restriction duration: Level 2	94	days
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG2.10d	WS14	Water restriction duration: Level 3	0	days
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG2.10e	WS15	Water restriction duration: Level 4	0	days
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG2.10f	WS16	Water restriction duration: Level 5	0	days

Year	Organisation	Scheme ID	Scheme	KPI Code	SWIM Code	Indicator Title	Value	Units
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG2.11a	WS17	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG2.11b	WS18	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG2.11c	WS19	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG2.11d	WS20	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG2.11e	WS21	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	yes	yes/no
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG2.12	WS22	Months water supply remaining as at 30 June (KPI level)	5	1,2,3,4,5,6
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG2.13	WS23	Confidence water demand will be met: next 18 mths	high	high,fair,unsure,low,very low
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG2.14	WS24	Confidence water demand will be met: next 5 yrs	fair	high,fair,unsure,low,very low
2021	Fraser Coast Regional Council	9559	Fraser Coast WSP-wide	QG2.3	WS3	Available contingency supplies	yes	yes/no